



KT2023002 - Cerámica muro Caspio Bianco

FORMATO / SIZE		33,3 X 90 cms. RECT.		
GRUPO / GROUP		BIII		
TIPO / TYPE		Revestimiento Pasta Blanca / White Body Wall Tile		
DESCRIPCION DEL TEST / TEST DESCRIPTION		VALOR DEL TEST / TEST VALUE	KERATILE	NORMA / STANDARD
ABSORCIÓN DE AGUA / WATER ABSORPTION		AA > 10%	Cumple / Passed	UNE-EN-ISO 10545-3
FUERZA DE ROTURA / BREAKING STRENGTH		> 600 N	Cumple / Passed	UNE-EN-ISO 10545-4
RESISTENCIA A LA FLEXIÓN / RESISTANCE OF FLEXION		> 12 N/mm ²	Cumple / Passed	UNE-EN-ISO 10545-4
ABRACION SUPERFICIAL / SURFACE ABRASION		Clase / Class	No aplica / Not requested	UNE-EN-ISO 10545-7
RESISTENCIA AL CUARTEO / CRACKING RESISTANCE		Requerido / Requested	Cumple / Passed	UNE-EN-ISO 10545-11
RESISTENCIA A LA HELADA / FROST RESISTANCE		Metodo disponible / Available method	No aplica / Not requested	UNE-EN-ISO 10545-12
RESISTENCIA QUIMICA / CHEMICAL RESISTANCE	(PRODUCTOS DOMESTICOS Y DE PISCINA / Domestic & Swimming Pool Products)	Mínimo / Minimum GB	Cumple / Passed	UNE-EN-ISO 10545-13
RESISTENCIA A LOS ACIDOS / ACID RESISTANCE		GHA	Cumple / Passed	UNE-EN-ISO 10545-13
RESISTENCIA A LAS BASES / ALKALINE RESISTANCE		GHA	Cumple / Passed	UNE-EN-ISO 10545-13
RESISTENCIA A LAS MANCHAS / RESISTANCE TO STAINS		Mínimo / Minimum Class 3	Cumple / Passed	UNE-EN-ISO 10545-14
RESISTENCIA AL DESLIZAMIENTO / SLIP RESISTANCE		Metodo Disponible / Available Method	No aplica / Not requested	UNE-41901 2017 EX
RESISTENCIA AL RAYADO / HARDNESS (MOHS)		Mínimo / Minimum 3	Cumple / Passed	EN 101

SRI16012.024/J116012024

KERATILE S.L.U.
 CIF B-12943336
 Calle del Ferrocarril, 4
 12593 Moncolá (Castellón) Spain
 Tel. +34 964 584 069 - Fax +34 964 584 070